



Ref. Certif. No.

HU-002277

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-switch-disconnector double opening

Name and address of the applicant

Zhejiang GRL Electric Co., Ltd.
No.246, Weishi Road, Economic Development Zone,
Yueqing City, Zhejiang Prov. 325600, P. R. China

Name and address of the manufacturer

Zhejiang GRL Electric Co., Ltd.
No.246, Weishi Road, Economic Development Zone,
Yueqing City, Zhejiang Prov. 325600, P. R. China

Name and address of the factory

Zhejiang GRL Electric Co., Ltd.
No.246, Weishi Road, Economic Development Zone,
Yueqing City, Zhejiang Prov. 325600, P. R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

3P, Ui=1000V, Uimp=12kV, AC 50/60Hz;
AC-23B: AC 400V, Ie=350/400/425/500/630A, 100kA;
AC-22B: AC 500V, Ie=350/400/425/500/630A, 100kA;
AC-21B: AC 690V, Ie=350/400/425/500A, 50kA;

Trademark (if any)

GRL

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DNH18-630/3a (a is variable, a=0, 1 or blank)
/for details see General product information of the Test Report/

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

03401-2018004A-S

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEEH
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu



Date: 2018-07-06

Signature:

Tünde Potencsik